CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7165-1615:143 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450

Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

DESIGN: Model SAFECOM 9000. Central station or proprietary service. Refer to listee's data sheet

for detailed product description and operational considerations. System components:

*D6600 Receiver SP-300 Printer RF-2000 RF Modem CM-100 Watchdog Unit

SC-4000, SC-4000F Subscriber Control Unit

*D6690 Line Card *D6691 Expansion Card

*D6695 RS232 Terminator Card

INSTALLATION: In accordance with listee's printed installation instructions, applicable code & ordinances and

in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an auxiliary control unit for use with separately listed compatible fire alarm control

units.

This control unit meets the requirements of UL-864, 8th Edition Standard.

NOTE: 1. Burglary and other non-fire functions were not examined. Refer to listee's data sheet or

installation instructions for compatible non-fire devices.

FORMERLY: 7165-1325:100, 7165-1383:100, and 7165-0801:173

*Rev 10-04-2005 JW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 29, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division